

本局於107年09月01日至30日台灣自來水股份有限公司第七區管理處所屬自來水供水系統管線採樣水質檢驗結果如下：

高雄市政府稿

檢驗項目			自由有效餘氯	pH值	濁度	總硬度	總溶解固體量	氯鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	砷	鉛	鐵	銀	鋅	銅	鉻	錳	鋁	硫酸鹽	總三鹵甲烷	大腸桿菌群	總菌落數	
受檢單位	序號	採樣日期	0.2~1.0 (mg/L)	6.0~8.5	2 (NTU)	300 (mg/L)	500 (mg/L)	250 (mg/L)	0.1 (mg/L)	0.1 (mg/L)	10 (mg/L)	0.01 (mg/L)	0.01 (mg/L)	0.3 (mg/L)	0.05 (mg/L)	5 (mg/L)	1 (mg/L)	0.05 (mg/L)	0.05 (mg/L)	0.3 (mg/L)	250 (mg/L)	0.08 (mg/L)	6 (CFU/100mL)	100 (CFU/mL)	
		飲用水水質標準																							
	1	107.09.03	岡山1	0.39	7.4	0.30	133	156	7.28	0.02	ND	0.45	ND	ND	0.015	ND	ND	ND	0.001	0.001	-	45.3	ND	<1	<1
	2	107.09.03	燕巢1	0.61	7.3	0.10	287	436	5.02	0.02	ND	1.41	ND	0.001	0.010	0.002	0.037	0.007	0.001	0.001	-	131	ND	<1	<1
	3	107.09.04	左1	0.42	7.4	0.30	106	140	8.50	ND	ND	0.29	ND	ND	0.013	ND	0.026	0.002	0.001	0.001	-	31.9	0.0182	<1	<1
	4	107.09.04	左3	0.56	7.6	0.30	108	136	7.45	0.02	ND	0.26	ND	ND	0.010	ND	0.006	ND	ND	<0.001	-	30.6	0.0182	<1	<1
	5	107.09.04	左5	0.54	7.6	0.25	98.2	138	8.08	ND	ND	0.25	ND	ND	0.010	ND	0.010	ND	0.001	<0.001	-	28.7	0.0187	<1	<1
	6	107.09.04	楠5	0.49	7.5	0.30	100	128	7.27	0.03	ND	0.26	ND	ND	0.009	ND	0.016	ND	ND	<0.001	-	31.2	0.0190	<1	<1
	7	107.09.04	楠4	0.57	7.6	0.30	130	172	7.17	0.02	ND	0.45	ND	0.001	0.015	0.001	0.007	ND	0.001	0.001	-	46.5	0.0179	<1	<1
	8	107.09.04	楠6	0.46	7.6	0.30	112	148	7.38	0.02	ND	0.35	ND	ND	0.010	ND	ND	ND	0.001	0.001	-	37.8	0.0167	<1	<1
	9	107.09.05	大樹1	0.51	7.7	0.20	200	272	3.73	ND	ND	0.75	ND	ND	0.005	ND	0.007	ND	0.001	<0.001	-	77.6	0.00599	<1	<1
	10	107.09.10	鳥松1	0.57	7.5	0.10	148	213	3.89	0.02	<0.01	0.65	ND	ND	0.003	ND	ND	ND	ND	-	63.1	0.00382	<1	<1	
	11	107.09.10	鳳山1	0.59	7.3	0.10	215	326	15.8	0.02	ND	0.41	ND	ND	0.005	ND	0.001	0.004	ND	<0.001	-	69.3	0.0218	<1	<1
	12	107.09.10	大寮2	0.42	7.2	0.10	154	228	10.4	ND	ND	0.53	ND	ND	0.007	ND	0.019	0.006	ND	0.001	-	58.9	0.0253	<1	<1
	13	107.09.10	大寮1	0.74	7.2	0.05	235	345	19.3	ND	<0.01	0.06	0.001	ND	0.006	ND	ND	0.006	ND	0.001	-	60.4	0.00413	<1	<1
	14	107.09.11	前1	0.32	7.5	0.15	138	189	5.32	0.02	<0.01	0.58	ND	ND	0.006	ND	ND	ND	ND	<0.001	-	56.1	0.0136	<1	<1
	15	107.09.11	前7	0.46	7.6	0.20	147	214	9.85	0.02	<0.01	1.38	0.001	ND	0.018	ND	ND	ND	ND	0.001	-	68.8	0.0289	<1	<1
	16	107.09.11	前4	0.49	7.5	0.15	145	234	10.6	ND	<0.01	1.45	0.001	ND	0.006	ND	0.005	ND	ND	ND	-	73.2	0.0321	<1	<1
	17	107.09.11	旗2	0.40	7.6	0.15	158	229	10.6	ND	<0.01	1.44	ND	ND	0.004	ND	ND	0.003	ND	ND	-	70.6	0.0326	<1	<1
	18	107.09.11	旗3	0.33	7.6	0.10	146	228	10.6	0.02	<0.01	1.48	ND	ND	0.005	ND	ND	ND	ND	ND	-	67.5	0.0385	<1	<1
	19	107.09.11	小5	0.53	7.8	0.15	144	234	10.8	0.02	<0.01	1.45	ND	ND	0.006	ND	0.007	ND	ND	<0.001	-	76.4	0.0264	<1	<1
	20	107.09.11	小1	0.39	7.8	0.15	146	216	10.9	ND	<0.01	1.54	ND	ND	0.005	ND	0.006	ND	ND	ND	-	66.8	0.0315	<1	<1
	21	107.09.11	小三	0.58	7.5	0.10	127	180	8.83	ND	<0.01	0.49	0.001	ND	0.003	ND	0.009	ND	ND	<0.001	-	44.5	0.0217	<1	<1
	22	107.09.12	美濃1	0.56	7.2	0.15	250	375	7.25	ND	<0.01	2.18	ND	0.002	0.012	ND	0.022	0.021	ND	<0.001	-	59.7	ND	<1	<1
	23	107.09.12	美濃2	0.87	7.3	0.10	239	358	5.10	ND	ND	2.74	ND	0.001	0.007	ND	0.015	0.010	ND	ND	-	56.7	ND	<1	<1
	24	107.09.12	六龜1	0.51	7.5	0.45	193	301	2.06	ND	<0.01	0.29	ND	ND	0.014	ND	ND	ND	ND	0.001	-	87.8	0.00121	<1	<1
	25	107.09.12	六龜2	0.64	7.7	0.40	206	313	2.32	0.02	<0.01	0.40	ND	ND	0.014	ND	0.006	ND	ND	0.001	-	84.6	0.00141	<1	<1
	26	107.09.12	茂林1	0.65	7.4	0.15	78.6	146	3.72	0.02	ND	2.34	ND	ND	0.005	ND	ND	ND	ND	ND	-	19.7	0.00372	<1	<1

本局於107年09月01日至30日台灣自來水股份有限公司第七區管理處所屬自來水供水系統管線採樣水質檢驗結果如下：

高雄市政府

項目			檢驗	自由有效餘氯	pH值	濁度	總硬度	總溶解固體量	氯鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	砷	鉛	鐵	銀	鋅	銅	鉻	錳	鋁	硫酸鹽	總三鹵甲烷	大腸桿菌群	總菌落數
序號	採樣日期	飲用水水質標準	0.2~1.0 (mg/L)	6.0~8.5	2 (NTU)	300 (mg/L)	500 (mg/L)	250 (mg/L)	0.1 (mg/L)	0.1 (mg/L)	10 (mg/L)	0.01 (mg/L)	0.01 (mg/L)	0.3 (mg/L)	0.05 (mg/L)	5 (mg/L)	1 (mg/L)	0.05 (mg/L)	0.05 (mg/L)	0.3 (mg/L)	250 (mg/L)	0.08 (mg/L)	6 (CFU/100mL)	100 (CFU/mL)	
27	107.09.12	茂林2	0.56	7.4	0.15	70.9	152	3.79	ND	ND	2.33	ND	ND	0.005	ND	0.006	0.005	ND	0.001	-	19.7	0.00489	<1	<1	
28	107.09.17	苓1	0.49	7.3	0.20	143	259	6.31	ND	ND	0.68	ND	ND	0.005	ND	0.007	ND	ND	ND	-	71.7	0.00812	<1	<1	
29	107.09.17	苓2	0.34	7.5	0.05	139	246	7.34	ND	ND	0.93	ND	ND	0.005	ND	0.032	ND	ND	ND	-	76.1	0.0116	<1	<1	
30	107.09.17	鹽新前5	0.35	7.5	0.15	139	273	13.7	0.02	ND	1.93	ND	ND	0.005	ND	0.006	ND	ND	ND	-	68.9	0.0198	<1	<1	
31	107.09.17	三6	0.50	7.4	0.05	139	268	5.28	0.03	ND	0.73	ND	ND	0.018	ND	0.007	ND	ND	ND	-	76.7	0.00619	<1	<1	
32	107.09.17	三1	0.49	7.5	0.05	139	246	6.57	ND	<0.01	0.65	ND	ND	0.009	ND	0.007	ND	ND	ND	-	68.0	0.00878	<1	<1	
33	107.09.17	三2	0.73	7.3	0.10	118	166	10.5	ND	ND	0.29	ND	ND	0.003	ND	ND	ND	ND	ND	-	37.0	0.0177	<1	<1	
34	107.09.18	塩新前2	0.54	7.5	0.10	136	238	5.81	0.02	ND	0.66	0.002	ND	0.007	ND	0.010	ND	ND	ND	-	71.7	0.00852	<1	<1	
35	107.09.18	塩新前7	0.45	7.4	0.10	140	229	10.4	0.02	ND	1.50	ND	ND	0.008	ND	0.005	ND	ND	ND	-	67.4	0.0179	<1	<1	
36	107.09.18	塩新前4	0.44	7.6	0.10	137	258	9.45	ND	ND	1.40	ND	ND	0.006	ND	0.007	ND	ND	ND	-	69.8	0.0138	<1	<1	
37	107.09.18	鼓1	0.51	7.5	0.15	138	218	8.79	0.03	ND	0.45	ND	ND	0.009	ND	0.011	ND	ND	<0.001	-	49.7	0.0170	<1	<1	
38	107.09.18	鼓3	0.47	7.4	0.15	142	263	5.85	0.03	ND	0.70	ND	0.001	0.023	ND	0.005	ND	ND	0.001	-	73.1	0.0125	<1	<1	
39	107.09.25	旗山1	0.52	7.7	0.10	274	432	5.12	0.02	ND	1.22	ND	0.004	0.020	ND	0.007	0.007	0.001	0.005	-	125	ND	<1	<1	
40	107.09.25	內門1	0.35	7.9	0.10	110	152	7.30	0.03	ND	0.19	ND	0.005	0.010	ND	ND	ND	0.002	ND	-	32.1	0.0240	<1	<1	
41	107.09.25	甲仙1	0.53	7.7	0.10	149	216	2.06	ND	ND	0.37	ND	0.004	0.019	ND	ND	ND	ND	0.001	0.199	66.6	0.00691	<1	<1	
42	107.09.25	甲仙2	0.54	7.8	0.10	147	221	2.06	ND	ND	0.37	ND	0.004	0.014	ND	ND	ND	ND	ND	0.194	66.1	0.00727	<1	<1	