

本局於105年06月01日至30日台灣自來水股份有限公司第七區管理處所屬自來水供水系統管線採樣水質檢驗結果如下：  
高雄市政府稿

檢驗項目			自由有效餘氯	pH值	濁度	總硬度	總溶解固體量	氯鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	砷	汞	鉛	鐵	銀	鋅	銅	鉻	錳	鋁	硫酸鹽	總三鹵甲烷	大腸桿菌群	總菌落數
受檢單位	採樣日期	飲用水水質標準	0.2~1.0 (mg/L)	6.0~8.5	2 (NTU)	300 (mg/L)	500 (mg/L)	250 (mg/L)	0.1 (mg/L)	0.1 (mg/L)	10 (mg/L)	0.01 (mg/L)	0.002 (mg/L)	0.01 (mg/L)	0.3 (mg/L)	0.05 (mg/L)	5 (mg/L)	1 (mg/L)	0.05 (mg/L)	0.05 (mg/L)	0.3 (mg/L)	250 (mg/L)	0.08 (mg/L)	6 (CFU/100 mL)	100 (CFU/mL)
1	105.06.01	鳥松1(配)	0.58	7.6	0.10	158	288	11.40	0.04	ND	0.28	0.002	ND	ND	0.006	ND	0.004	ND	0.001	0.001	-	103	0.0027	<1	<1
2	105.06.01	大樹1(配)	0.58	7.7	0.15	197	314	12.60	0.02	ND	0.36	0.001	ND	ND	0.010	ND	0.005	ND	0.001	0.001	-	88.6	0.0165	<1	<1
3	105.06.02	燕巢1(配)	0.77	7.6	0.10	265	428	5.40	0.03	ND	1.41	ND	ND	0.001	0.017	0.001	0.021	0.009	0.001	0.001	-	121	0.0177	<1	<1
4	105.06.02	岡山1(配)	0.65	7.9	0.15	217	325	11.10	0.03	ND	0.47	ND	ND	0.001	0.018	ND	0.005	ND	ND	0.001	-	94.6	0.0176	<1	<1
5	105.06.13	鳳山1(配)	0.67	7.9	0.10	180	254	9.61	0.02	ND	0.30	ND	ND	0.001	0.015	ND	0.012	0.004	0.002	0.001	-	88.5	0.0138	<1	<1
6	105.06.13	大寮2(配)	0.69	7.5	0.10	168	274	9.03	0.03	ND	0.29	ND	ND	0.001	0.007	0.001	0.015	0.004	0.001	0.001	-	65.8	0.0110	<1	<1
7	105.06.13	大寮1(配)	0.77	7.5	0.10	177	251	11.80	ND	ND	0.35	ND	ND	0.001	0.012	ND	0.023	0.010	0.001	0.001	-	74.4	0.0116	<1	<1
8	105.06.14	左2(配)	0.52	7.8	0.20	145	222	13.4	0.03	<0.01	0.33	ND	ND	ND	0.010	0.001	0.004	ND	0.001	0.001	-	68.1	0.0136	<1	<1
9	105.06.14	左6(配)	0.41	7.7	0.20	171	240	19.0	0.03	<0.01	0.71	ND	ND	0.001	0.028	ND	0.007	ND	ND	0.001	-	55.1	0.0194	<1	<1
10	105.06.14	左4(配)	0.40	7.7	0.15	156	221	18.6	0.03	<0.01	0.57	ND	ND	0.001	0.009	ND	0.008	ND	0.001	0.001	-	51.9	0.0152	<1	<1
11	105.06.14	楠2(配)	0.61	7.7	0.25	156	213	15.1	0.02	ND	0.34	ND	ND	ND	0.010	ND	0.006	0.003	0.001	0.001	-	54.3	0.0159	<1	<1
12	105.06.14	楠1(配)	0.40	7.8	0.15	159	236	15.90	0.03	ND	0.46	ND	ND	0.001	0.011	0.001	0.017	0.003	ND	0.001	-	56.9	0.0151	<1	<1
13	105.06.14	楠5(配)	0.52	7.7	0.15	151	221	15.20	0.03	ND	0.34	ND	ND	ND	0.014	ND	0.008	0.002	ND	0.001	-	58.0	0.0178	<1	<1
14	105.06.15	前2(配)	0.45	7.8	0.20	137	281	31.00	0.02	ND	3.70	0.001	ND	0.001	0.019	ND	0.015	0.002	0.001	0.001	-	76.7	0.0641	<1	<1
15	105.06.15	前6(配)	0.39	7.8	0.20	139	289	31.30	0.03	ND	3.83	0.001	ND	0.001	0.015	ND	0.009	0.002	0.001	0.001	-	74.2	0.0619	<1	<1
16	105.06.15	前5(配)	0.35	7.8	0.20	137	288	31.70	0.03	ND	3.94	0.001	ND	0.001	0.012	0.001	0.007	ND	0.001	0.001	-	72.7	0.0588	<1	<1
17	105.06.15	前3(配)	0.35	7.9	0.20	147	297	28.40	0.03	ND	3.83	0.001	ND	ND	0.015	0.002	0.010	0.002	ND	0.001	-	66.2	0.0631	<1	<1
18	105.06.15	旗1(配)	0.38	7.8	0.15	140	326	28.60	0.02	<0.01	3.88	ND	ND	ND	0.009	0.001	0.011	0.002	0.001	0.001	-	69.5	0.0645	<1	2
19	105.06.15	小2(配)	0.36	7.6	0.10	175	327	16.70	0.03	ND	1.30	0.001	ND	0.002	0.018	0.002	0.019	0.003	ND	0.001	-	74.4	0.0239	<1	<1
20	105.06.15	小4(配)	0.52	7.7	0.15	160	291	17.90	0.02	ND	1.77	ND	ND	0.001	0.012	ND	0.005	ND	0.001	0.001	-	74.9	0.0372	<1	<1
21	105.06.20	甲仙1(配)	0.48	8.3	0.25	133	222	14.60	0.02	ND	0.37	ND	0.0002	0.002	0.023	0.002	0.015	0.004	0.001	0.003	0.223	60.2	0.0151	<1	<1
22	105.06.20	甲仙2(配)	0.37	8.3	0.25	137	229	14.40	ND	ND	0.38	ND	ND	0.001	0.018	0.002	0.016	0.004	0.002	0.004	0.198	63.5	0.0124	<1	<1
23	105.06.21	三4(配)	0.44	7.7	0.10	149	245	11.50	ND	ND	0.38	0.001	ND	0.001	0.020	0.006	0.024	0.002	0.004	0.001	-	83.4	0.0060	<1	<1
24	105.06.21	三5(配)	0.49	7.7	0.10	148	239	11.60	ND	ND	0.37	0.001	ND	0.001	0.011	0.002	0.022	0.002	0.002	0.001	-	77.3	0.0168	<1	<1
25	105.06.21	三3(配)	0.57	7.3	0.10	149	244	11.50	ND	ND	0.39	0.002	ND	ND	0.013	0.002	0.007	0.003	0.001	<0.001	-	80.2	0.0053	<1	<1
26	105.06.21	三7(配)	0.67	7.6	0.10	169	252	11.60	0.04	ND	0.45	0.001	ND	0.001	0.007	0.002	0.021	0.002	0.002	<0.001	-	73.8	0.0106	<1	<1

本局於105年06月01日至30日假台灣自來水股份有限公司第七區管理處所屬自來水供水系統管線採樣水質檢驗結果如下：

## 高雄市政府

項目			檢驗	自由有效餘氯	pH值	濁度	總硬度	總溶解固體量	氯鹽	氨氮	亞硝酸鹽氮	硝酸鹽氮	砷	汞	鉛	鐵	銀	鋅	銅	鉻	錳	鋁	硫酸鹽	總三鹵甲烷	大腸桿菌群	總菌落數
序號	採樣日期	飲用水水質標準	0.2~1.0 (mg/L)	6.0~8.5	2 (NTU)	300 (mg/L)	500 (mg/L)	250 (mg/L)	0.1 (mg/L)	0.1 (mg/L)	10 (mg/L)	0.01 (mg/L)	0.002 (mg/L)	0.01 (mg/L)	0.3 (mg/L)	0.05 (mg/L)	5 (mg/L)	1 (mg/L)	0.05 (mg/L)	0.05 (mg/L)	0.3 (mg/L)	250 (mg/L)	0.08 (mg/L)	6 (CFU/100mL)	100 (CFU/mL)	
27	105.06.21	鼓4(配)	0.35	7.6	0.10	172	250	14.60	0.03	ND	0.59	ND	ND	0.001	0.009	0.002	0.011	ND	0.002	0.001	-	67.4	0.0182	<1	<1	
28	105.06.21	鼓2(配)	0.30	7.8	0.10	167	246	11.60	0.03	ND	0.37	0.001	ND	ND	0.008	0.002	0.013	ND	0.001	0.001	-	79.6	0.0104	<1	<1	
29	105.06.22	苓4(配)	0.58	7.3	0.15	150	246	11.20	ND	ND	0.41	ND	ND	0.001	0.010	0.002	0.008	0.002	0.002	<0.001	-	77.0	0.0074	<1	<1	
30	105.06.22	苓5(配)	0.50	7.6	0.15	148	248	11.90	ND	ND	0.42	ND	ND	0.001	0.006	0.002	0.007	0.002	0.002	0.001	-	80.3	0.0105	<1	<1	
31	105.06.22	苓3(配)	0.51	7.7	0.10	127	234	4.30	ND	ND	0.59	ND	ND	0.002	0.013	0.002	0.018	0.003	0.002	0.001	-	83.9	0.0079	<1	<1	
32	105.06.22	鹽新前1(配)	0.49	7.7	0.10	140	233	8.28	ND	ND	0.48	0.001	ND	ND	0.007	0.002	0.014	0.002	0.002	0.001	-	82.8	0.0127	<1	<1	
33	105.06.22	鹽新前3(配)	0.54	7.7	0.10	151	257	11.40	ND	ND	0.41	0.001	ND	0.001	0.014	0.002	0.032	0.002	0.002	0.001	-	81.3	0.0084	<1	<1	
34	105.06.22	鹽新前6(配)	0.53	7.8	0.10	143	256	11.10	ND	ND	0.41	0.001	ND	0.002	0.026	0.001	0.015	0.002	0.002	0.001	-	82.4	0.0065	<1	<1	
35	105.06.27	旗山1	0.63	7.6	0.20	267	388	4.92	0.02	ND	1.08	0.001	ND	0.001	0.034	ND	0.009	0.006	0.001	0.005	-	114.0	ND	<1	<1	
36	105.06.27	內門1	0.68	7.8	0.25	127	192	6.62	ND	ND	0.25	ND	ND	ND	0.015	ND	0.010	0.001	0.001	0.002	-	45.8	0.0334	<1	<1	
37	105.06.27	美濃1	0.73	7.4	0.20	250	350	7.02	0.02	ND	2.15	ND	ND	0.001	0.014	ND	0.014	0.017	0.001	0.001	-	58.2	ND	<1	<1	
38	105.06.27	美濃2	0.52	7.4	0.20	251	337	6.94	ND	ND	2.16	ND	ND	0.001	0.006	ND	0.012	0.012	0.001	ND	-	58.2	ND	<1	<1	
39	105.06.28	茂林1	0.36	7.8	0.10	135	182	2.54	ND	ND	1.37	ND	ND	ND	0.006	ND	0.005	0.001	0.001	0.001	-	41.2	0.0014	<1	<1	
40	105.06.28	茂林2	0.49	7.8	0.10	128	185	3.20	0.03	ND	1.37	ND	ND	ND	0.007	ND	0.013	0.005	0.001	<0.001	-	44.5	0.0048	<1	5	
41	105.06.29	六龜1(配)	0.62	8.0	0.10	182	274	2.43	0.04	<0.01	0.21	ND	ND	ND	0.011	ND	0.007	0.001	0.001	0.001	-	89.6	0.0010	<1	<1	
42	105.06.29	六龜2(配)	0.54	8.0	0.10	195	302	2.44	0.03	ND	0.21	ND	ND	0.001	0.023	ND	0.006	0.001	0.001	0.001	-	86.2	0.0008	<1	<1	